

# EVOO7 CONTROL


## Installation cordon « Silent Mode »

- ➔ Couper l'alimentation électrique de votre PAC.
- ➔ Connecter le cordon sur la prise «OPTION X6A» de la carte de contrôle du groupe DAIKIN (unité extérieure).
- ➔ Remettre l'alimentation et votre PAC restera tout le temps en « Silent Mode »

	RZQ 71	RZQ 100	RZQ 125
Réduction du bruit	4 dBA	4dBA	5 dBA



Le mode « Silent » de Daikin permet de réduire le bruit de votre PAC, en limitant la vitesse du compresseur et des ventilateurs. La puissance totale de la machine se retrouvera alors limité à 70-80% de sa puissance totale.



A close-up photograph of a computer motherboard. The focus is on the DB-F91-101 connector, which is a small, black, rectangular component. A yellow label with the text "SILENT MODE" is attached to the connector. The motherboard is green and populated with various components, including capacitors, resistors, and integrated circuits. The text "DB-F91-101" is printed on the board near the connector. The background is a light-colored, textured surface.